OLD FILE NAME: 15Q 37.DGN

PREPARED BY:		SANDIA NATIONAL LABORATORIES FACILITIES ENGINEERING	DETAIL NO.: MH5011
CHECKED BY:			SCALE: NONE
DATE: 6-15-01	REV: A	R.A. GRILLE SOUND ELBOW	MECHANICAL STANDARD



KEYED NOTES

1. SECURE SOUND ELBOW TO RETURN GRILLE. TAPE TO GRILLE AS REUIRED.
2. RETURN AIR GRILLE IN CEILING. SEE PLANS AND SCHEDULE FOR SIZE AND TYPE.
3. COORDINATE SOUND ELBOW INSTALLATION WITH STRUCTURE, LIGHT FIXTURES AND OTHER OBSTRUCTIONS.
4. MAINTAIN SAME FACE AREA AS GRILLE (MIN.).
5. SUPPORT WITH SHEETMETAL STRAPS FROM STRUCTURE SIMILAR TO DUCTWORK.
6. CONSTRUCT SOUND ELBOW OF SHEETMETAL W/1" INTERIOR ACOUSTIC LINING.
   PAINT INSIDE FLAT BLACK TO BE LIGHT-TIGHT.

"Property of Sandia National Laboratories Facilities Management and Operation Center (FMOC).
No duplication or alteration allowed without the expressed permission and authorization of FMOC."