OLD FILE NAME: 15Q 25.DGN

PREPARED BY:		SANDIA NATIONAL LABORATORIES FACILITIES ENGINEERING	DETAIL NO.: MJ5004
CHECKED BY:			SCALE: NONE
DATE: 6-15-01	REV: B	EXHAUST FAN SIGN	MECHANICAL STANDARD

DANGER

BEFORE TURNING OFF FAN

NOTIFY THE PERSONNEL IN THE FOLLOWING ROOMS DURING NORMAL WORKING HOURS.

DURING NON-WORKING HOURS A VISUAL INSPECTION IS REQUIRED FOR EACH ROOM LISTED BELOW TO INSURE THAT NO EXHAUST SYSTEM IS IN CRITICAL OPERATION BEFORE THE FAN OR FANS ARE TURNED OFF

BASEMENT ROOMS:

SECOND FLOOR ROOMS:

FIRST FLOOR ROOMS:

THIRD FLOOR ROOMS:

"Property of Sandia National Laboratories Facilities Management and Operation Center (FMOC).
No duplication or alteration allowed without the expressed permission and authorization of FMOC."