PREPARED BY: E. L. GORE	SANDIA NATIONAL LABORATORIES FACILITIES ENGINEERING	FILE NAME: WG5004STD.DGN
CHECKED BY: D. CAMPBELL		SCALE: NONE
DATE: 1/15/03 REV:	MARKER POST WITH TEST BOX DETAIL	CIVIL WORKS STANDARD

MARKER POST W/TEST BOX FOR USE IN TA-III AND ALL REMOTE AREAS UNLESS OTHERWISE NOTED. SEE WG5003STD "TEST BOX DETAIL" FOR USE IN TA-I, II, IV & V, AND ROADWAYS & PEDESTRIAN WALKWAYS. LOCATE POST AT EACH VALVE CLUSTER, EACH PIPING CHANGE OF DIRECTION, EVERY 200' MAXIMUM SPACING, AND AS SHOWN ON PROJECT DWGS.

DRAWING SYMBOL (T)



SECTION

"Property of Sandia National Laboratories Facilities Management and Operation Center (FMOC). No duplication or alteration allowed without the expressed permission and authorization of FMOC."